


TURKISH POWER SYSTEM

- The sole owner of Electricity Transmission System
- Responsible for the expansion of transmission network infrastructure & construction of new transmission facilities
- Operating & Maintaining the Turkish Electricity Transmission Network in economic and reliable manner, in compliance with international standards
- Monitoring real-time system reliability, purchasing Ancillary Services
- Preparing Generation Capacity Projection
- Developing international connections






SUBSTATIONS

400 kV : 97
220 kV : 1
154 kV : 584
66 kV : 13
Total : 695 Subs.
with 133,744 MVA capacity


TRANSMISSION LINES

400 kV : 18,484,4 km
154 kV : 37,579,0 km
220 kV : 84,5 km
66 kV : 509,4 km
154 & 400 kV Cable: 337,7 km
Total : 56,995 km

Year	Consumption (TWh)	Increase (%)
1998	114,0	8,1
1999	118,5	3,9
2000	128,3	8,3
2001	126,9	-1,1
2002	132,6	4,5
2003	141,2	6,5
2004	150,0	6,3
2005	160,8	7,2
2006	174,6	8,6
2007	180,0	8,8
2008	188,1	4,3
2009	194,1	-2,0
2010	210,4	8,4
2011	230,3	9,4
2012	242,3	5,2
2013	246,3	1,8
2014	257,2	4,4




INSTALLED CAPACITY




INSTALLED CAPACITY BY PRIMARY SOURCE (October 2015)

Primary Source	Installed Capacity (MW)
Total	72.455,4
Natural Gas	21.304,7
Coal+Lignite	14.787,5
Geothermal	614,2
Hydro	25.648,7
Wind	4.280,7
PV	203,1
Other	5.616,5




PRODUCED ENERGY BY PRIMARY SOURCES (2014)


Total	251.962,8 TWh
Natural Gas	120.576,0
Coal+Lignite	75.308,5
Geothermal	2.364,0
Hydro	40.644,7
Wind	8.520,1
PV	17,4
Others	4.532,1



OWNERSHIP IN GENERATION



LOCATION OF THE PPS




16 November 2015, Istanbul

TEİAŞ 11

PEAK LOAD & TRANSMISSION LOSSES


Year	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014
(%)	3.26	2.95	2.84	2.85	2.88	2.68	2.48	2.26	2.82	2.40	2.25	2.27	2.67




16 November 2015, Istanbul

TEİAŞ 12

WIND ENERGY DEVELOPMENT



GEOTHERMALS




31.10.2015	
Installed Capacity	614,2 MW
Licences given	137,3 MW
Pre-licence given	451,3 MW
Total	1202,8 MW

According to Ministries Stragegy Paper:


- Using All economic HPP potential (135 billion kWh)
- Reaching 20.000 MW Wind installed Capacity
- Reaching at least 3.000 MW PV installed capacity
- Reaching at least 600 MW Geothermal installed capacity
- Bio-mass 1.500 MW

YILARA GÖRE TÜRKİYE'NİN KURULU GÜCÜ, PUNANT TALEBİ VE SİSTEME BAĞLANABİLİR RÜZGAR KAPASİTESİ




OPERATION OF THE POWER SYSTEM

TEIAS



- 1 NCC
- 9 RCC
- 22 Regional Center in charge of Maintenance&Investments




16 November 2015, Istanbul

TEIAS 17

EXISTING INTERCONNECTIONS

TEIAS



16 November 2015, Istanbul

TEIAS 18


- 41 TSO - 34 countries
- 992.4 GW Net Generation Capacity
- 528.9 GW Peak Load
- 305,000km EHV TL
- 3,274 TWh/year consumption
- 380TWh/year exchange
- 530 million citizens served


System Development

System Operation

Electricity Market

Research and Development





- Get benefit of synchronous parallel operation
- Integration of the “Turkish Electricity Market” with “Internal Electricity Market” of EU

Technical

- Security of supply
- Increasing the quality of electricity


Economical

- Decreasing hot and cold reserves
- Decreasing the need for installed capacity -> postponing the investments
- Developing electricity trade

Other

- Protecting the environment
-

- Frequency control quality improvement
- Risk of inter area oscillations
- Measures against propagation of disturbances




TEIAS



2000

Application

PPC (GR)



UCTE Steering Committee



Consider all possibilities of synchronous connection

UCTE System Development Working Group



"Turkey's Connection"
Sub-Group



TEIAS 27

16 November 2015, Istanbul

TEIAS

"Complementary Studies for the Synchronisation of Turkish Power System with UCTE System"


Budget : 1.5 Million €
EC through the programme of Pre-accession Financial Assistance for Turkey as a 2003 Programme



16 November 2015, Istanbul

TEIAS 28

- The system interconnection of Turkey to UCTE is **feasible** under following conditions:
 - ▶ the existing inherent frequency control problem is resolved
 - ▶ positive damping effect of AVR for the 0,15 Hz inter-area oscillations is assured in the majority of generation units
- A Special Protection Scheme at the interface is necessary to manage extreme contingencies
- The power transfer from Turkey to UCTE must not exceed 500MW during the trial operation



Implementation of the measures defined in 1. Project



HPP Name	Units	Rated Power (MW)	T _{av} [s]	Objective Modification	Operational Importance	Rehabilitation or Returning		Onsite tuning
						Short Term (2009-2010)	Long Term	
Atatürk	8x315	2520	2,7...3,95		Base load	Rehabilitation		completed
Karakaya	6x315	1890	1,06...1,24		Base load	Rehabilitation		completed
Birecik	6x120	860	2,17		Base load	Returning		completed
Keban	4x175	700	2,35...2,46		Base load	Returning	Rehabilitation	completed
	4x201	804	2,37...2,46		Base load	Returning	Rehabilitation	Same as first 4 units
Athinaya	4x195	780	0,92		Base load	Returning	Rehabilitation	completed
Oymapınar	4x150	600	0,79		Peak load	Rehabilitation		completed
Berke	3x187	561	0,41		Peak load	Returning		completed
Hasan Uğurlu	4x145	580	1,52		Base load	Returning		completed
Sir	3x105	315	0,35		Peak load	Returning		completed
Gökçekaya	3x105	315	-		Peak load	Returning	Rehabilitation	Same as Keban
Borca	2x167	334	1-1,2		Peak load	Returning		completed
TOTAL		10299						

- Priority
- Island Mode Stability
- Primary Control activation (30s-ramp)

16 November 2015, İstanbul

Power Plant	Type	Power / MVA	Onsite tuning	Comments
Atatürk	HPP	8x315	completed	ABB+JTS
Karakaya	HPP	6x315	completed	ABB+JTS
Unluinar	CC	2x210 & 1x212	completed	Alstom
Temelli	CC	2x309 & 1x380	completed	GE+Alstom
Adapazari	CC	2x306 & 1x332	completed	GE+Alstom
Aliaga	CC	4x306 & 2x332	completed	GE+Alstom
Gebze	CC	4x306 & 2x332	completed	GE+Alstom
Elbistan B	TPP	4x403	completed	Mitsubishi+JTS
Isken	TPP	2x660	1st site worky 2nd one ASAP	Siemens USA
Oymapınar	HPP	4x150	completed	Vatech+JTS
TOTAL		~ 14000 MW		

16 November 2015, İstanbul

TEİAŞ

OBJECTIVE

- ▶ to prevent the propogation of the disturbance to ENTSO-E in case of extreme contingency in Turkish EPS (Big Load or generation trip)
- ▶ to keep working in synchronous mode with ENTSO-E as long as possible
- ▶ to make sure load flow on interconnections within limits
- ▶ to prevent Turkish EPS disconnect from ENTSO-E due to angular or voltage instability by load scheduling or generation tripping

16 November 2015, Istanbul

TEİAŞ 33


TEİAŞ

- Survey of the power plants
- Design of governor control¶meter optimization
- Secondary Control optimization
- Training
- 10240 MW Hydro Rehabilitated or returned
- 8 TPP Rehabilitated
- 14000 MW AVR&PSS returned
- Modifying SVC (± 1150 MVAR)
- Installation of STATCOM (± 50 MVAR)
- Installation of Special Protection System


16 November 2015, Istanbul

TEİAŞ 34


FREQUENCY IMPROVEMENT



ISOLATED TESTS




SYNCHRONIZATION



16 November 2015, Istanbul

SUCCESSFUL OPERATION OF TEIAS



16 November 2015, Istanbul

MILESTONES

Milestone	Date
Complementary Studies for the Synchronisation of Turkish Power System with UCTE System	2005 - 2007
Rehabilitation of the Frequency Control Performance of Turkish Power System for Synchronous Operation with UCTE	2007 - 2009
Contractual Agreement between ENTSO-E & TEIAS	18 December 2009
Isolated Operation Test (Peak Load)	11-24 January 2010
Isolated Operation Test (Min. Load)	22 March-5 April 2010
Synchronisation and Synchronous Parallel Operation Test Phase 1	18 September 2010
Synchronous Parallel Operation Test Phase 2	21 Feb.-7 March 2011
Synchronous Parallel Operation Test Phase 3	1 June 2011 -
Increase of FNTCs	17 April 2013
Decision for Permanent Synchronous Operation	9 & 24 April 2014
Signing of the Long Term Agreement	15th April 2015

BENEFITS

- More stable frequency -> more stable network
- Reduction of Primary reserve around 500 MW
- Cross-border trade
- Integration of the "Turkish Electricity Market" with "Internal Electricity Market" of EU


CROSS-BORDER TRADE



TEIAS


TEIAS

- TCAT Platform for TR-BG border
 - Monthly auctions
 - Daily and Yearly in 2016
 - SEE CAO for TR-GR border
 - Yearly, Monthly and Daily auctions
 - Yearly auctions for non-synchronous borders
 - Explicit auctions
 - TCAT Platform
 - Auction
 - Auction Announcements
 - Auction Results
 - Secondary Market
 - Counterparty Notification
 - Nomination
 - Auction Rules, other documents
 - Registered Users List
 - Announcements
 - Maintenance Periods
 - Curtailments
 - Contact Information
 - Turkish/English
- <https://www.teias.gov.tr/>
- 16 November 2015, Istanbul



TEIAS | 42


COMMERCIAL FLOWS



16 November 2015, Istanbul

TEIAS 43


MONTHLY AUCTION PRICES



16 November 2015, Istanbul

TEIAS 44

SOUTH EAST EUROPE COORDINATED AUCTION OFFICE (SEE CAO)



Trader has to win 3 auctions with

- 3 different Auction system
- 3 different Product
- 3 different Time Horizons

A successful transaction is only possible if the trader wins all 3 auctions.

TEIAS



- Only:
- 1 Auction System
 - 1 Product
 - 1 Time Horizon

Traders bid for a source sink combination and a loadflow calculation software analyzes the possible power flows in the grid

TEIAS

7 TSO established SEE CAO

Limited Liability Company

Location: Montenegro

AAMHE

GTS

MW HOPS

KCSB

OST

TEIAS

TEIAS


- 1st successful regional project
- Trading in 7 countries
- One-stop shop
- Common rules & procedures
- Following of the EU legislative
 - in EU and non EU countries
- New products in SE energy market
- Provided transparency – connection with ENTSO-E
Transparency Platform



BENEFITS

TEIAS

- 7 different systems → Single Auction Platform located in Podgorica
- <http://www.seecao.com>
- Web based application
- Synchronised auctions
- Single procedure, standard, rules, registration




TECHNICAL APPROACH

TEIAS

BLACKOUT ON 31ST MARCH




SYSTEM CONDITIONS BEFORE THE BLACKOUT



16 November 2015, Istanbul

- Ordinary working day
- Medium load demand
- Main maintenance period for TR
- Spring water regime with full load operation of hydro power plants in Eastern Turkey
- Heavy loadlow for TR East->West transmission system corridor

SYSTEM CONDITIONS BEFORE THE BLACKOUT



- 32950 MW system load
- 500 MW import from CE
- 4800 MW east -> west power flow
- 21870 MW west load
- 11080 MW east load
- 21% imbalance west
- 42% imbalance east
- Scheduled line outages due to maintenance and system expansion
 - (4 out of 11 in East-Wear Corridor)
- Series capacitors for long transmission lines out of service

SEQUENCE OF EVENTS

#	Line/Event	Date (local)	Time (UTC)	Phase (MW)	Active Power (MW)	Reactive Power (MVA)	Number of Buses	Comment
1	Kurşunlu-Osmanca	2	09:50:08.418	1127	810	283	1318	Tripped
2	Aydıncık-Tuzluca	2	09:50:10.884	950	931	333	1450	Line A is tripped. Ground fault alarm. The system is in a state of emergency. The system is in a state of emergency.
3	Seydihan-Kahramanmaraş	1	09:54:11.015	887	697	236	2133	Tripped
4	Sivas-Erzincan B	1	09:56:11.142	813	887	248	1982	Tripped
5	Sivas-Erzincan A	1	09:58:11.204	423	1054	203	2100	Tripped
6	Ardahan-Turkmeneli	1	09:58:11.265	464	1194	338	2000	Line A is tripped. Ground fault alarm. The system is in a state of emergency. The system is in a state of emergency.
7	Tarsus-Yahşın	1	09:58:11.282	348	1030	318	1880	Tripped
8	Tarsus-Yahşın	1	09:58:11.317	51	1381	346	2000	Tripped
9	Kozan-Çukurova	2	09:58:12.441	440	288	150	2233	Tripped
10	Antalya-Viranşehir	2	09:58:12.462	238	228	150	2028	Phase A opens. In Case 2 (1)
11	Tarsus-Yahşın	2	09:58:12.528	821	200	165	2058	Tripped



- First line trip in Kurşunlu-Osmanca
- Second and following lines trip due to low impedance or out of step
- In 3.1 seconds TR arrives in two islands
- In 10-12 seconds total system blackout

ACTIVATED DEFENCE PLANS

TEİAŞ

- Interface Special Protection Scheme
- Underfrequency load shedding
 - Four steps
 - 49.0 Hz; 48.8 Hz; 48.6 Hz; 48.4 Hz
 - Current setting = 35.5% load at 48.4 Hz
- 52.3 Hz eastern island
- 48.2 Hz western island
- Power plant disconnections due to high frequency deviations

Region	West Island		East Island		TOTAL
	SPS	TEİAŞ			
Trance	232 MW	1641 MW			1893 MW
Northwest Anatolia	125 MW	1018 MW			1143 MW
West Anatolia		1059 MW			1059 MW
Southwest Mediterranean		516 MW			516 MW
Middle Anatolia		585 MW	204 MW		787 MW
Northeast Anatolia			242.2 MW		242.2 MW
East Anatolia			0		0
South East Anatolia			683 MW		683 MW
Southeast Mediterranean			1148.1 MW		1148.1 MW
TOTAL	377 MW	4817 MW	2377.2 MW		7471.3 MW

Frequency Range	Minimum duration
51.5 Hz - 51.5 Hz - 52.5 Hz	10 minutes
50.5 Hz - 51.5 Hz - 51.5 Hz	1 hour
49 Hz - 51.5 Hz - 50.5 Hz	Permanent
48.5 Hz - 51.5 Hz - 49 Hz	1 hour
48 Hz - 51.5 Hz - 48.5 Hz	20 minutes
47.5 Hz - 51.5 Hz - 48 Hz	10 minutes


RESTORATION

TEİAŞ

- Top-down (CE) and bottom-up (9 regional centers) procedures in parallel
- Start with TR-BG connection after 18 minutes
- After 1 ½ hours 50% of Trace region was energised
- East-West synchronisation at 16:12 (after 6.5 hours) – 80% of load restored
- Mobile communication was not affected
- Airline traffic was not affected

Time (CE)	Percentage of system load restored
09:36	Blackout
12:00	20%
14:30	50%
16:12	80%
18:30	95%


RESTORATION PHASE



16 November 2015, Istanbul

TEİAŞ 57

RESTORATION PHASE



12:30


16 November 2015, Istanbul

TEİAŞ 58

RESTORATION PHASE

13:00(EET) %20 Completed

13:30




16 November 2015, Istanbul

RESTORATION PHASE

15:30(EET) %50 Completed

15:30



16 November 2015, Istanbul

RESTORATION PHASE


TEIAS

17:12(EET) %80 Completed

49.90 Hz

17:00

49.65 Hz



16 November 2015, İstanbul

TEIAS 61

RESTORATION PHASE


TEIAS

19:30(EET) %95 Completed

50.02 Hz


19:30

50.02 Hz



16 November 2015, İstanbul

- Uncoordinated transmission line outages
- Disconnection of series capacitors
- Incomplete SCADA system functionality
- System operation close to operational margins
- Non-conform power plant protection settings
- Insufficient underfrequency load shedding



Report on Blackout in Turkey on 31st March 2015

– Final Version 1.0 –
Project Group Turkey
21 September 2015

- Available in ENTSO-E and TEIAS web sites

Report Authors:

- TEIAS experts
- PG Turkey members
- SPD experts

Source of Data & Information:

- TEIAS maps, operational database
- WAM measurements
- TSO & PP SCADA recordings
- TSO timely high resolution recordings

Thank you for your attention!

Mehmet KARA

Plananning and Strategic Management Dep.

hmehmet.kara@teias.gov.tr

TEIAS

